

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAQ681		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner OREGON, VILLAGE OF						Phone # (608)835-3441							
Mailing Address 117 SPRING STREET						1. Well Location Village of OREGON						Fire # (if avail.)	
City OREGON				State WI		Zip Code 53575							
County Dane		Co. Permit #		Notification #		Completed 11-28-2022		Subdivision Name			Lot #	Block #	
Well Constructor (Business Name) MUNICIPAL WELL & PUMP/MIDWEST WELL				Lic. # 13	Facility ID # (Public Wells) 113025110						Method Code GPS008		
Address 1212 STORBECK DR WAUPUN WI 53963				Well Plan Approval # W2021-0939		or Govt Lot #	Section 3	Township 5 N		Range 9 E			
Hicap Permanent Well # 92840		Common Well # 006		Specific Capacity 15.5				2. Well Type New Well					
3. Well serves # of VILLAGE				Hicap Well ? Yes		of previous unique well # constructed in							
Drillhole				Hicap Property ? Yes		Reason for replaced or reconstructed well ?							
Heat Exchange ___ # of drillholes				Hicap Potable ? Yes		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method						8. Geology							
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole			Lower Open Bedrock			Geology Codes	8. Geology Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)	To (ft.)
20	Surface	40	<u>No</u>	Rotary - Mud Circulation		<u>No</u>	T	C	G	M	T-TAN/BROWN C-CLAY	Surface	15
19	40	438	<u>No</u>	Rotary - Air		<u>No</u>		G	M		G-GRAVEL/STONES M-SILTY	15	32
15	438	992	<u>No</u>	Rotary - Air & Foam		<u>No</u>	T	B	Y		T-TAN/BROWN B-BROKEN Y-SAND & GRAVEL	32	38
			<u>No</u>	Drill-Through Casing Hammer			T		N	G	T-TAN/BROWN N-SANDSTONE G-W/GRAVEL/STONES	38	290
			<u>No</u>	Reverse Rotary			Y		N	H	Y-YELLOW N-SANDSTONE H-SHALEY	290	435
			<u>No</u>	Cable-tool Bit ___in. dia...		<u>No</u>	I		N		I-WHITE N-SANDSTONE	435	980
			<u>Yes</u>	Dual Rotary		<u>No</u>	T		N	H	T-TAN/BROWN N-SANDSTONE H-SHALEY	980	992
			<u>Yes</u>	Temp. Outer Casing 20in. dia									
			<u>No</u>	Removed? 40depth ft. (If NO explain on back side)									
6. Casing, Liner, Screen													
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)	To (ft.)							
20	ASTM A53B, SEAH STL WELDED, 0.375" WALL				Surface	40							
16	ASTM A53B, SEAH STL WELDED, 0.375" WALL				0	438							
Dia. (in.)	Screen type, material & slot size				From (ft.)	To (ft.)							
7. Grout or Other Sealing Material													
Method TREMIE PIPE - PUMPED													
Kind of Sealing Material		From (ft.)	To (ft.)	# Sacks Cement									
NEAT CEMENT		Surface	438	475 S									

9. Static Water Level

171 ft. below ground surface

11. Well Is

24 in. above grade

10. Pump Test

Pumping level 238 ft. below surface

Pumping at 1040 GP M for 24 Hrs.

Pumping Method ? Test Pump

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

No

Filled & Sealed Well(s) as needed?

No

13. Constructor / Supervisory Driller

Lic #

Date Signed

TG

4135

11-28-2022

Drill Rig Operator

Lic or Reg #

Date Signed

MR

7819

11-28-2022

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Comment:

Water Quality Text:

Water Quantity Text:

Difficulty Text:

Created On: 02-01-2023

Created by: MWPUMP

Updated On: 06-28-2023

Updated by: WELL PROCESS